



Certificate of Compliance

Certificate: 1167625 (LR 44092)

Master Contract: 152450

Project: 2223395

Date Issued: 2009/10/14

Issued to: Micro Motion Incorporated

7070 Winchester Cir
Boulder, CO 80301
USA

Attention: Ray C. Stengl

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Ron Wachowicz, C.E.T.

Issued by: Ron Wachowicz, C.E.T.

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -
Certified to US Standards

CLASS 2258 03 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non -
Incendive Systems - For Hazardous Locations

CLASS 2258 83 - PROCESS CONTROL EQUIPMENT-Intrinsically Safe and Non-
Incendive - Systems-For Hazardous Locations-Certified to U.S. Standards

2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations - To US Requirements

Class I, Division 2, Groups A, B, C and D; Class II, Division 1, Groups E, F and G:

R Series Sensors; Maximum Ambient +60°C; Temperature Code T3A. Models R025: MWP 2320 PSI; R050: MWP 1500 PSI; R100 and R200: MWP 1450 PSI; Dual Seal.

CNG Series Sensors; Maximum Ambient +60°C; Temperature Code T3A. Models CNG 050: MWP 5000 PSI; Dual Seal.



Certificate: 1167625 (LR 44092)

Master Contract: 152450

Project: 2223395

Date Issued: 2009/10/14

2258- 03 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non-Incendive Systems For Hazardous Locations

2258- 83 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non-Incendive Systems For Hazardous Locations - To US Requirements

Class I, Division 1, Groups C and D; Class I, Division 2, Groups A, B, C and D; Class II, Division 1, Groups E, F and G:

R Series Sensors; Intrinsically Safe: Ambient of -40 to +60°C; Temperature Code T3A. Models R025: MWP 2320 PSI; R050: MWP 1500 PSI; R100 and R200: MWP 1450 PSI; Dual Seal. Sensors are intrinsically safe when connected per installation instructions Type CSA-D-IS.

CNG Series Sensors; Intrinsically Safe: Ambient of -40 to +60°C; Temperature Code T3A. Model CNG 050: MWP 5000 PSI; Dual Seal. Sensor is intrinsically safe when connected per installation instructions Type CSA-D-IS.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No 0 M1991 - General Requirements - Canadian Electrical Code Part II.

CSA Standard C22.2 No 25-M1966 - Enclosures for use in Class II, Groups E, F, and G Hazardous Locations

CSA Standard C22.2 No 94-M1991 - Special Purpose Enclosures.

CSA Standard C22.2 No 142-M1987 - Process Control Equipment.

CSA Standard C22.2 No 157-M1992 - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations.

CSA Standard C22.2 No 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Div 2 Hazardous Locations.

UL 50, Eleventh Edition - Enclosures for Electrical Equipment

UL 508, Seventeenth Edition - Industrial Control Equipment.

UL 913, Seventh Edition - Intrinsically Safe Apparatus and Associated Apparatus for use in Class I, II, III, Division 1, Hazardous (Classified) Locations.

UL 1203, Fourth Edition - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations.

UL 1604, Third Edition - Electrical Equipment for Use in Class I and II, Division 2, And Class III Hazardous (Classified) Locations.

ANSI/ISA 12.27.01: 2003 - Requirements for Process Sealing Between Electrical Systems and Flammable or Combustible Process Fluids.